

TUV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD
ZERTIFIKAT ◆ CERTIFICATE ◆ 認證書 ◆ CERTIFICADO ◆ CERTIFICAT



Product Service

CERTIFICATE

No. Z2 108181 0001 Rev. 00

Holder of Certificate: **ET SOLAR POWER HONGKONG LIMITED**

Room 01,21/F, XINGFA Commercial Building
9th Tobacco Factory Street
Mong Kok
HONG KONG

Certification Mark:



Product:

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Mono-crystalline Silicon Photovoltaic module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 704061941101-00

Valid until: 2025-05-05

Date, 2020-05-06 (Zhulin Zhang)



A4 / 07.17



Product Service

CERTIFICATE

No. Z2 108181 0001 Rev. 00

Model(s): 144 cells module: ET-M672BHxxxGL, xxx=385-405 in step of 5;
120 cells module: ET-M660BHxxxGL, xxx=325-335 in step of 5;
xxx is standing for rated output power at STC.

Parameters:

Construction:	Framed, with Junction box, cable and connector.
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute, No. 10 West Kaifa Road, Yangzhou 225009 Jiangsu, P. R. China.
Safety Class:	Class II
Max. system voltage:	1500V DC
Fire Safety Class:	Class A according to UL790

Tested according to:

- IEC 61215-1(ed.1)
- IEC 61215-1-1(ed.1)
- IEC 61215-2(ed.1)
- IEC 61730-1(ed.2)
- IEC 61730-2(ed.2)

Production Facility(ies): 101631

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD
ZERTIFIKAT ◆ CERTIFICATE ◆ 認證書 ◆ CERTIFICADO ◆ CERTIFICAT